

Binghamton City School District

**DISTRICT-WIDE**
**LEAD-IN-DRINKING WATER**

 BHS, EM, WM SCHOOLS  
 EM, WM & MAC FIELD HOUSES  
 & MAINTENANCE FACILITY  
 Binghamton, New York

**UPDATED: 1/7/2019**
**CODING SYSTEM:**

 CDF - Classroom Drinking Fountain  
 CS - Classroom Sink  
 DF - Drinking Fountain  
 DS - Dentist Sink  
 HECS - Home Ec. Class Sink  
 IM - Ice Maker  
 JS - Janitor Sink  
 KS - Kitchen Sink  
 NS - Nurses Sink  
 LBS - Library Sink  
 LS - Laundry Sink  
 PS - Principals Office Sink  
 PES - Physical Education Sink  
 SC - Service Connection  
 SES - Special Education Sink  
 TLS - Teachers Lounge Sink

\* A value of zero indicates "below detectable limits of analysis"

DESIGNATION NUMBER	LOCATION	SOURCE TYPE CODE	RESULT (PPB) *	COMMENT
<b>BENJAMIN FRANKLIN ELEMENTARY</b>				
BF-LDW-001	Main Level Classroom 109	CDF	1	
BF-LDW-004	Lower Level Faculty Room	KS	2	
BF-LDW-005	Lower Level Pre-K Classroom 14	CDF	3	
BF-LDW-006	Lower Level Corridor C	DF	1	
BF-LDW-007	Lower Level Corridor B	DF	0	
BF-LDW-008	Main Level East Lobby #1 - High	DF	0	
BF-LDW-009	Main Level East Lobby #2 - Low	DF	0	
BF-LDW-010	Main Level Kitchen #1 - Left	KS	0	
BF-LDW-011	Main Level Kitchen #2 - Right	KS	1	
BF-LDW-012	Main Level Kitchen #3 - Center Island	KS	4	
BF-LDW-013	Main Level Kitchen	IM	0	
BF-LDW-014	Main Level Classroom 110	SES	1	
BF-LDW-015	Main Level West Lobby #1 - High	DF	0	
BF-LDW-016	Main Level West Lobby #2 - Low	DF	0	
BF-LDW-017	Main Level Corridor D	DF	0	
BF-LDW-018	Main Level Health, exam room	NS	0	
BF-LDW-019	Main Level Room 101 B	NS	4	
BF-LDW-020	Main Level Corridor B	DF	0	
BF-LDW-021	Second Level Staff 210 D	TLS	6	
BF-LDW-022	Second Level Classroom 206	TLS	0	
BF-LDW-023	Second Level Corridor B #1 - Left	DF	1	
BF-LDW-024	Second Level Corridor B #2 - Right	DF	0	
BF-LDW-025	Second Level Corridor C #1 - Left	DF	1	
BF-LDW-026	Second Level Corridor C #2 - Right	DF	0	
BF-LDW-027	Third Level Room 306	DS	8	
<b>CARLISLE COMMUNITY CENTER</b>				
CCC-LDW-001	FIRST FLOOR CORRIDOR,	DF	0	
CCC-LDW-002	KITCHEN NEAR BREAK ROOM	KS	0	

DESIGNATION NUMBER	LOCATION	SOURCE TYPE CODE	RESULT (PPB) *	COMMENT
<b>CALVIN COOLIDGE ELEMENTARY</b>				
CC-LDW-001	First Floor Nurse's Room 129	NS	1	
CC-LDW-002	First Floor Room 133 (Kitchen #1)	KS	4	
CC-LDW-004	First Floor Room 120	TLS	3	
CC-LDW-005	First Floor Room 128A	PS	4	
CC-LDW-006	First Floor Room 133 (Kitchen # 2)	KS	1	
CC-LDW-007	First Floor Corridor 127 D	DF	3	
CC-LDW-008	First Floor Corridor 127 A (North #1)	DF	2	
CC-LDW-009	First Floor Corridor 127 A (South #2)	DF	2	
CC-LDW-010	Second Floor Room 221	TLS	9	
CC-LDW-011	Second Floor Corridor 222 (North #1)	DF	6	
CC-LDW-012	Second Floor Corridor 222 (South #2)	DF	3	
<b>COLUMBUS SCHOOL</b>				
CS-LDW-001	First Floor, Nurses 110	NS	0	
CS-LDW-002	First Floor, Nurses 110 A	BS	0	
CS-LDW-003	First Floor, Classroom 115	HECS	0	
CS-LDW-004	First Floor, Corridor A	DF	0	
CS-LDW-005	First Floor, Corridor D	DF	0	
CS-LDW-006	Second Floor, Cafeteria #1	KS	1	
CS-LDW-007	Second Floor, Cafeteria #2	KS	1	
CS-LDW-008	Second Floor, Corridor A	DF	0	
CS-LDW-009	Second Floor, Corridor C	DF	0	
CS-LDW-010	Third Floor, Board Room 307 A	TLS	4	
CS-LDW-011	Third Floor, Copier Room 305 G	TLS	0	
CS-LDW-012	Third Floor, Corridor B # 1	DF	0	
CS-LDW-014	Third Floor, Corridor A	DF	0	
<b>EAST MIDDLE SCHOOL</b>				
EM-LDW-002	First Level, Classroom 103 #1	HECS	8	
EM-LDW-003	First Level, Classroom 103 #2	HECS	3	
EM-LDW-004	First Level, Classroom 103 #3	HECS	8	
EM-LDW-005	First Level, Classroom 103 #4	HECS	11	
EM-LDW-006	First Level, Classroom 105 #1	HECS	6	
EM-LDW-007	First Level, Classroom 105 #2	HECS	7	
EM-LDW-008	First Level, Classroom 105 #3	HECS	2	
EM-LDW-009	First Level, Classroom 105 #4	HECS	9	
EM-LDW-010	First Level, Kitchen #1 (Prep & Rinse)	KS	2	
EM-LDW-011	First Level, Kitchen #2 (Prep & Rinse)	KS	6	
EM-LDW-012	First Floor Kitchen B #3 (Coffee Pot ONLY)	KS	4	
EM-LDW-013	First Level, Kitchen #4 (Sprayer)	KS	4	
EM-LDW-014	First Level, Kitchen #5 (Steamer)	KS	4	
EM-LDW-015	First Level, Kitchen #6 (Kettle)	KS	9	
EM-LDW-016	First Level, Kitchen	IM	3	
EM-LDW-017	First Level, Corridor F	DF	0	
EM-LDW-018	First Level, Corridor E	DF	1	
EM-LDW-019	Second Level, Nurses Office Room 214 # 1	NS	3	
EM-LDW-020	Second Level, Gymnasium - East	DF	3	
EM-LDW-021	Second Floor Corridor C	DF	5	
EM-LDW-022	Second Floor Corridor B #1	DF	3	
EM-LDW-023	Second Floor Corridor A	DF	6	
EM-LDW-024	Second Floor Corridor B #2	DF	3	
EM-LDW-025	Third Floor Corridor A #1	DF	5	
EM-LDW-026	Third Floor Corridor A #2	DF	3	
EM-LDW-027	Third Floor Corridor C	DF	3	
EM-LDW-028	Third Floor Corridor B	DF	0	
EM-LDW-029	Fourth Floor Corridor C	DF	4	
EM-LDW-030	Fourth Floor Corridor B	DF	4	
EM-LDW-031	Fourth Floor Corridor A	DF	0	

DESIGNATION NUMBER	LOCATION	SOURCE TYPE CODE	RESULT (PPB) *	COMMENT
EM-LDW-032	Fourth Floor Corridor D	DF	3	
EM-LDW-033	Second Floor Gymnasium -West	DF	4	
EM-LDW-034	Second Floor Teacher's Lounge	TLS	4	
<b>EAST MIDDLE FIELD HOUSE</b>				
EMFH-LDW-001	First Floor, Room 101 #1	KS	1	
EMFH-LDW-002	First Floor, Room 101 #2	KS	5	
EMFH-LDW-003	First Floor, Room 110	JS	2	90 second flush before use
<b>THOMAS JEFFERSON</b>				
TJ-LDW-003	Third Floor, Corridor A	DF	0	
TJ-LDW-004	Second Floor, Corridor A	DF	1	
TJ-LDW-005	First Floor, Nurses Office -Room 9	NS	0	
TJ-LDW-006	First Floor, Kitchen (Left)	KS	2	
TJ-LDW-007	First Floor, Kitchen (Right)	KS	1	
TJ-LDW-008	First Floor, Corridor A	DF	1	
TJ-LDW-009	First Floor, Corridor C	DF	0	
TJ-LDW-010	First Floor, Faculty- Room 1	TLS	3	
<b>MAINTENANCE FACILITY</b>				
MF-LDW-001	First Floor, Room 8	KS	9	
MF-LDW-002	First Floor, Room 14	DF	24	removed sink 6/2016
<b>BINGHAMTON HIGH SCHOOL</b>				
BHS-LDW-003	Building B, First Floor, Kitchen #3- Tilting Skillet	KS	6	filter installed
BHS-LDW-004	Building B, First Floor, Kitchen #8	KS	11	
BHS-LDW-010	Building B, Second Floor, Corridor B-B	DF	4	
BHS-LDW-015	Building B, Fourth Floor, Room B 407 ½	TLS	11	
BHS-LDW-022	Building A, Fourth Floor, Classroom A 404 Office	TLS	0	new faucet and filter
BHS-LDW-025	Building C, First Floor, Concession (Counter-Sink)	KS	0	
BHS-LDW-026	Building C, First Floor, Concession (Foot-Pedal Sink)	KS	86	hand wash sink, removed from service 8/2016
BHS-LDW-028	Building D, Basement Floor, Corridor D-A	DF	15	removed from service 3/2016
BHS-LDW-030	Building B, First Floor, Room B 101	HECS	1	
BHS-LDW-031	Building B, First Floor, Coffee Shop-B100A	SES	2	
BHS-LDW-032	Building B, First Floor, Room B 103	DF	4	
BHS-LDW-033	Building B, First Floor, Room B 104	KS	3	
BHS-LDW-034	Building B, First Floor, Corridor B-D	DF	2	
BHS-LDW-035	Building B, First Floor, fast food kitchen, 1132 (Left)	KS	14	
BHS-LDW-036	Building B, First Floor, fast food kitchen, 1132 (Middle)	KS	5	
BHS-LDW-037	Building B, First Floor, fast food kitchen, 1132 (Right)	KS	4	
BHS-LDW-038	Building A, First Floor, Corridor A-A	DF	435	removed from service
BHS-LDW-039	Building B, Second Floor, Corridor B-A	DF	2	
BHS-LDW-040	Building B, Second Floor, Storage	TLS	5	
BHS-LDW-041	Building B, Second Floor, Nurses Office B 207 A	NS	1	

DESIGNATION NUMBER	LOCATION	SOURCE TYPE CODE	RESULT (PPB) *	COMMENT
BHS-LDW-042	Building B, Second Floor, Nurses Office B 209 D	BS	5	
BHS-LDW-043	Building A, Second Floor, Room A 202	TLS	6	
BHS-LDW-044	Building A, Second Floor, Corridor A-A	DF	0	
BHS-LDW-045	Building A, Third Floor, Corridor A-A	DF	1	
BHS-LDW-046	Building B, Third Floor, Corridor B-A	DF	1	
BHS-LDW-047	Building A, Third Floor, Library 3034	TLS	8	
BHS-LDW-048	Building B, Third Floor, Break Room/ PT Room	SES	14	
BHS-LDW-049	Building B, Third Floor, Corridor B-B	DF	8	
BHS-LDW-050	Building A, Fourth Floor, Corridor A-A	DF	4	filter installed
BHS-LDW-051	Building B, Fourth Floor, Corridor B-A	DF	1	
BHS-LDW-052	Building B, Fourth Floor, Corridor B-B	DF	4	
BHS-LDW-053	Building C, First Floor, Corridor C-A (High)	DF	3	
BHS-LDW-054	Building C, First Floor, Corridor C-A (Low)	DF	3	
BHS-LDW-055	Building C, First Floor, Corridor C-B (High)	DF	2	
BHS-LDW-056	Building C, First Floor, Corridor C-B (Low)	DF	4	
BHS-LDW-057	Building C, Second Floor, Corridor C-B	DF	5	
BHS-LDW-058	Building C, Third Floor, Corridor C-B	DF	12	
BHS-LDW-059	Building C, Basement Floor, Corridor @ Pool	DF	0	
BHS-LDW-060	Building D, First Floor, Corridor D-A	DF	4	
BHS-LDW-061	Building D, Second Floor, Corridor D-B	DF	0	
BHS-LDW-062	Building D, Basement Floor, Room D 107 A	BS	9	
BHS-LDW-063	Building B, First Floor, Kitchen #4	KS	11	
BHS-LDW-064	Building B, First Floor, Kitchen #5- Right Sink	KS	4	
BHS-LDW-065	Building B, First Floor, Kitchen #6-Left Sink	KS	31	Wash sink, removed from des. drinking list
BHS-LDW-066	Building B, First Floor, Kitchen #2	KS	3	
BHS-LDW-067	Building B, First Floor, Kitchen #1-Left Kettle	KS	1	
BHS-LDW-068	Building B, First Floor, Kitchen #7- Right Kettle	KS	2	
BHS-LDW-069	Building B, First Floor, Kitchen Ice maker	IM	0	
<b>HORACE MANN ELEMENTARY</b>				
HM-LDW-005	Second Floor Corridor A #4	DF	0	
HM-LDW-010	First Floor Classroom 107	CDF	11	
HM-LDW-011	First Floor Classroom 108	CDF	7	
HM-LDW-012	First Floor Classroom 113	CDF	2	
HM-LDW-013	First Floor Classroom 114	CDF	2	
HM-LDW-014	First Floor Café	DF	3	
HM-LDW-015	First Floor Corridor C #1	DF	4	
HM-LDW-016	First Floor Corridor C #2	DF	0	
HM-LDW-017	First Floor Kitchen #1 (Middle Left)	KS	12	
HM-LDW-018	First Floor Kitchen #2 (Middle Right)	KS	8	
HM-LDW-019	First Floor Main Office	TLS	9	
HM-LDW-020	First Floor Nurse Office	NS	6	
HM-LDW-021	Second Floor Room 227	TLS	10	
HM-LDW-022	Second Floor Corridor A #1	DF	0	
HM-LDW-023	Second Floor Corridor A #2	DF	4	
HM-LDW-024	Second Floor Corridor A #3	DF	9	
HM-LDW-025	Second Floor Corridor C #1	DF	9	
HM-LDW-026	Second Floor Corridor C #2	DF	0	
HM-LDW-027	Second Floor Corridor C #3	DF	7	
HM-LDW-028	Second Floor Corridor C #4	DF	10	
<b>THEODORE ROOSEVELT ELEMENTARY</b>				

DESIGNATION NUMBER	LOCATION	SOURCE TYPE CODE	RESULT (PPB) *	COMMENT
TR-LDW-001	First Floor, Nurses Room 1151	NS	1	
TR-LDW-008	First Floor, Nurses Exam Room 1152	NS	3	90 second daily flush
TR-LDW-009	First Floor, Health Room 1123	NS	0	
TR-LDW-010	First Floor, Health Room 1124	DS	0	
TR-LDW-011	First Floor, Health/Nurse Room (Bathroom)	BS	0	
TR-LDW-012	Third Floor, Corridor A (Left)	DF	0	
TR-LDW-013	Third Floor, Corridor A (Right)	DF	0	
TR-LDW-014	Second Floor, Corridor A	DF	0	
TR-LDW-015	First Floor, Room 1170	TLS	1	
TR-LDW-016	First Floor, Corridor E	DF	0	
TR-LDW-017	First Floor, Corridor C	DF	0	
TR-LDW-018	First Floor, Kitchen #1 (East-most wall)	KS	3	HAND WASH SINK, removed from des. drinking list 4/26/2017
TR-LDW-019	First Floor, Kitchen #2	KS	6	
TR-LDW-021	First Floor, Kitchen	IM	0	
<b>WEST MIDDLE SCHOOL</b>				
WM-LDW-001	Classroom sink, room 250	CS	83	LAB sink, removed from designated drinking list
WM-LDW-002	Fourth Floor, Home Economics Room 424 #1	HECS	3	
WM-LDW-003	Fourth Floor, Spec Ed. Teachers' Lounge Room 416	TLS	35	removed from service 8/2016
WM-LDW-004	BOILER ROOM	SC	4	
WM-LDW-005	First Floor, Kitchen #1 (Steamer)	KS	3	
WM-LDW-006	First Floor, Kitchen #2	KS	8	
WM-LDW-007	First Floor, Kitchen #3	KS	10	
WM-LDW-008	First Floor, Kitchen #4 (Kettle Faucet)	KS	9	
WM-LDW-009	First Floor, Kitchen #5	KS	5	
WM-LDW-010	First Floor, Kitchen	IM	3	
WM-LDW-011	First Floor, Corridor D	DF	10	
WM-LDW-012	First Floor, Café	DF	9	
WM-LDW-013	First Floor, Special Ed Room 114	SES	3	
WM-LDW-014	First Floor, Room 116	TLS	3	
WM-LDW-015	First Floor, Corridor C	DF	3	
WM-LDW-016	First Floor, Corridor A	DF	2	
WM-LDW-017	Second Floor, Corridor C	DF	5	
WM-LDW-018	Second Floor, Corridor A	DF	2	
WM-LDW-019	Second Floor, Nurses Office 254 C	NS	3	
WM-LDW-020	Second Floor, Nurses Office 254 B	NS	4	
WM-LDW-021	Second Floor, Nurses Office (Bathroom)	BS	2	
WM-LDW-022	Third Floor, Home Economics Room 324 #1	HECS	5	
WM-LDW-023	Third Floor, Home Economics Room 324 #2	HECS	5	
WM-LDW-024	Third Floor, Corridor C	DF	2	
WM-LDW-025	Third Floor, Corridor A	DF	2	
WM-LDW-026	Fourth Floor, Corridor C	DF	7	
WM-LDW-027	Fourth Floor, Corridor A	DF	5	
WM-LDW-028	Fourth Floor, Home Economics Room 414 #1	HECS	2	
WM-LDW-029	Fourth Floor, Home Economics Room 414 #2	HECS	5	
WM-LDW-030	Fourth Floor, Home Economics Room 414 #3	HECS	4	
WM-LDW-031	Fourth Floor, Home Economics Room 414 #4	HECS	4	
WM-LDW-032	Fourth Floor, Spec Ed. Teachers' Lounge Room 416	TLS	4	
WM-LDW-033	Fourth Floor, Spec Ed. Teachers' Lounge Room 416	TLS	5	
WM-LDW-034	Fourth Floor, Home Economics Room 424 #2	HECS	2	

DESIGNATION NUMBER	LOCATION	SOURCE TYPE CODE	RESULT (PPB) *	COMMENT
WM-LDW-035	Fourth Floor, Home Economics Room 424 #3	HECS	9	
WM-LDW-036	Fourth Floor, Home Economics Room 424 #4	HECS	5	
<b>WEST MIDDLE FIELD HOUSE</b>				
WMFH-LDW-001	EXTERIOR #1 (HIGH)	DF	0	
WMFH-LDW-002	EXTERIOR #2 (LOW)	DF	0	
<b>WOODROW WILSON ELEMENTARY</b>				
WW-LDW-001	Second Level, Room 215	TLS	6	
WW-LDW-003	Basement Level, Room 1112 (Bathroom) #1	BS	0	
WW-LDW-004	Basement Level, Room 1112 (Bathroom) # 2	BS	2	
WW-LDW-005	Basement Level, Room 1112 (Bathroom) #3	BS	0	
WW-LDW-006	Basement Level, Corridor A (Low)	DF	2	
WW-LDW-007	Basement Level, Corridor A (High)	DF	1	
WW-LDW-008	Lower Level, Corridor A	DF	3	
WW-LDW-009	Lower Level, Corridor C	DF	2	
WW-LDW-010	Basement Level, Room 1112 # 4	JS	0	
WW-LDW-011	Main Level, Kitchen #1	KS	2	HAND WASH SINK, removed from designated drinking list
WW-LDW-012	Main Level, Kitchen (Wash Sink) #2	KS	4	
WW-LDW-013	Main Level, Kitchen (Sprayer) #3	KS	1	
WW-LDW-014	Main Level, Nurses Room 112	BS	4	
WW-LDW-015	Main Level, Corridor A #2	DF	5	
WW-LDW-016	Main Level, Corridor C #1	DF	4	
WW-LDW-017	Main Level, Corridor C #2	DF	6	
WW-LDW-018	Second Level, Corridor A #2	DF	4	
WW-LDW-019	Second Level, Corridor C #1	DF	4	
WW-LDW-020	Second Level, Corridor C #2	DF	7	
WW-LDW-021	Main Level, Corridor A #1	DF		out of service
WW-LDW-022	Second Level, Corridor A #1	DF		out of service
<b>MACARTHUR ELEMENTARY</b>				
MAC-LDW-001	Main Bar – A1, First Floor Boys A113/Girls A114 #1 (High)	DF	0	
MAC-LDW-002	Main Bar – A2, First Floor, Cafeteria A141 #1 (High)	DF	0	
MAC-LDW-003	Main Bar – A3, First Floor, Passage 107 #1	DF	0	
MAC-LDW-004	North Wing, First Floor, Classroom B105	CDF	3	
MAC-LDW-005	North Wing, First Floor, Classroom B106	CDF	1	
MAC-LDW-006	North Wing, First Floor, Classroom B108	CDF	1	
MAC-LDW-007	North Wing, First Floor, Corridor B104 #1 (Low)	DF	0	
MAC-LDW-008	North Wing, Second Floor, Classroom B205	CDF	0	
MAC-LDW-009	North Wing, Second Floor, Classroom B206	CDF	0	
MAC-LDW-010	North Wing, Second Floor, Classroom B207	CDF	0	
MAC-LDW-011	North Wing, Second Floor, Corridor B204 #2 (High)	DF	0	
MAC-LDW-012	Middle Wing, First Floor, Classroom C106	CDF	3	
MAC-LDW-013	Middle Wing, First Floor, Classroom C107	CDF	0	
MAC-LDW-014	Middle Wing, First Floor, Classroom C108	CDF	1	
MAC-LDW-015	Middle Wing, First Floor, Corridor C104 #2 (High)	DF	0	
MAC-LDW-016	Middle Wing, Second Floor, Classroom C205	CDF	0	
MAC-LDW-017	Middle Wing, Second Floor, Classroom C207	CDF	0	
MAC-LDW-018	Middle Wing, Second Floor, Classroom C208	CDF	1	
MAC-LDW-019	Middle Wing, Second Floor, Corridor C204 #1 (Low)	DF	0	
MAC-LDW-020	Middle Wing, Second Floor, Corridor C204 #2 (High)	DF	0	
MAC-LDW-021	South Wing, First Floor, Classroom D103	CDF	7	
MAC-LDW-022	South Wing, First Floor, Classroom D108	CDF	1	
MAC-LDW-023	South Wing, First Floor, Classroom D109	CDF	1	

DESIGNATION NUMBER	LOCATION	SOURCE TYPE CODE	RESULT (PPB) *	COMMENT
MAC-LDW-024	South Wing, First Floor, Classroom D110	CDF	1	
MAC-LDW-025	South Wing, First Floor, Corridor D107 #1 (Low)	DF	0	
MAC-LDW-026	South Wing, Second Floor, OT/PT D203	DF	1	
MAC-LDW-027	South Wing, Second Floor, Classroom D205	CDF	3	
MAC-LDW-028	South Wing, Second Floor, Classroom D208	CDF	3	
MAC-LDW-029	South Wing, Second Floor, Classroom D209	CDF	0	
MAC-LDW-030	South Wing, Second Floor, Classroom D210	CDF	1	
MAC-LDW-031	South Wing, Second Floor, Classroom D211	CDF	0	
MAC-LDW-032	South Wing, Second Floor, Corridor D207 #1 (High)	DF	0	
MAC-LDW-033	Main Bar – A1, First Floor, Kitchenette A110A	TLS	2	
MAC-LDW-034	Main Bar – A1, First Floor, Health A112	NS	2	
MAC-LDW-035	Main Bar – A1, First Floor, Exam A112A	NS	1	
MAC-LDW-036	Main Bar – A1, First Floor Boys A113/Girls A114 #2 (Low)	DF	1	
MAC-LDW-037	Main Bar – A1, First Floor, Kid's Kitchen A143	KS	2	
MAC-LDW-038	Main Bar – A1, First Floor, Art A144	CDF	1	
MAC-LDW-039	Main Bar – A2, Performance Music A116	CDF	3	
MAC-LDW-040	Main Bar – A2, First Floor, General Music A115	CDF	3	
MAC-LDW-041	Main Bar – A2, Kitchen A140 (Food Prep)	KS	1	
MAC-LDW-042	Main Bar – A2, Kitchen A140 (Vegetable Prep)	KS	1	
MAC-LDW-043	Main Bar – A2, First Floor, Cafeteria A141 #2 (Low)	DF	1	
MAC-LDW-044	Main Bar – A3, First Floor, Passage 107 #2	DF	0	
MAC-LDW-045	Main Bar – A3, First Floor, Passage 108 #1 (High)	DF	0	
MAC-LDW-046	Main Bar – A3, First Floor, Passage 108 #2 (Low)	DF	1	
MAC-LDW-047	North Wing, First Floor, Classroom B107	CDF	2	
MAC-LDW-048	North Wing, First Floor, Corridor B104 #2 (High)	DF	1	
MAC-LDW-049	North Wing, Second Floor, Classroom B208	CDF	1	
MAC-LDW-050	North Wing, Second Floor, Corridor B204 #1 (Low)	DF	0	
MAC-LDW-051	Middle Wing, First Floor, Classroom C105	CDF	2	
MAC-LDW-052	Middle Wing, First Floor, Corridor C104 #1 (Low)	DF	0	
MAC-LDW-053	Middle Wing, Second Floor, Classroom C206	CDF	1	
MAC-LDW-055	South Wing, First Floor, Classroom D105	CDF	0	
MAC-LDW-056	South Wing, First Floor, Classroom D111	CDF	2	
MAC-LDW-057	South Wing, First Floor, Corridor D107 #2 (High)	DF	0	
MAC-LDW-058	South Wing, Second Floor, Classroom D212	CDF	1	
MAC-LDW-059	South Wing, Second Floor, Corridor D207 #2 (Low)	DF	0	
<b>MACARTHUR FIELD HOUSE</b>				
MACFH-LDW-001	EXTERIOR #1 (HIGH)	DF	1	
MACFH-LDW-002	EXTERIOR #2 (LOW)	DF	1	
<b>END</b>				